



TECHNICAL REQUIREMENT:

1. NOM VOLTAGE RATING, KV	69
2. DRY 60 HZ F O, KV	200
3. WET 60 HZ F O, KV	180
4. POS CRITICAL IMPULSE F O, KV	330
5. NEG CRITICAL IMPULSE F O, KV	425
6. 60 HZ TEST VOLTAGE, KV	44
7. MAX RIV AT 1000 KEZ, MV	200
8. CANTILEVER STRENGTH, LBS	2800
9. CANTILEVER PROOF TEST (MIN), LBS	1400
10. LEAKAGE DISTANCE, IN	53
11. DRY ARCING DISTSNCE, IN	19.25
12. APPLICABLE STANDARD	ANSI C29.7

6		BRAKE	1	Q235			
5		FITTING	1	QT450-10			
4		PORCELAIN	1	IV			
3		CEMENT					
2		CORK	1				
1		FITTING	1	QT450-10			
No	DRAWING No	NAME	QTY	MATERIAL	ONE WEIGHT	TOTAL WEIGHT	NOTE
				43790-7001		43	
				HORIZONTAL CLAMPTOP			
				LINE POST			
				INSULATOR			
SEN	QTY	REVISOR No	NAME	DATE			
DRAWN							
CHECKED							
APPROVE							
DATE							
					TOTAL 2 PAGES		PAGE 1